



COMMERCIAL POOL RESURFACING REQUIREMENTS

PROJECT ADDRESS: _____

- Include itemized list of all proposed work that is to be done
- Pool floor & walls shall be white or pastel in color with slip-resistant finish per Section 454.1.2.1 - 2014 FBC
- Depth markers and No Diving markers must be installed in accordance with Section 454.1.2.3.1 - 2014 FBC
- Underwater lighting must be in working condition and comply with Section 454.1.4.2.3 - 2014 FBC
- The lip of the gutter must be leveled to within ¼ inch between the highest and lowest points. Downward slope from the lip to the drain must be maintained as originally designed or increased per Section 454.1.6.5.3.1 - 2014 FBC
- Tile step markings shall be slip resistant and comply with Section 454.1.2.5.3 2014 FBC
- Pool Ladder must have 3 to 6 inch clearance from the pool wall. New cross braced ladders shall be installed in place of non-cross braced ladders in conformance with Section 454.1.2.5.1-2014 FBC during a pool resurfacing
- Where applicable the Slope Break marking must be installed meeting the requirements of Section 454.1.2.2.3 – 2014 FBC and Safety Line must be installed two feet before the marking
- Main drain cover replaced. Cover/grate shall comply with the requirements of ANSI/APSP 16 and Section 454.1.6.5.10 – 2014 FBC
- Pool Plans need to show pool layout, dimension of pool, steps, ladders, depth of pool, drains and lights
- Operating Permit for Health Department is: _____

Note: All tile step markings, horizontal depth marking and no diving markings must be non-skid tile.